¢

3" | 3"

TAG
SIDE

(2) LAYERS 5/8" TYPE "X"
GYP. BD. or BASE LAYER OF
TYPE "X" GYP. "SUREBOARD"
WHEN REQ'D BY STRUCTURAL

ACOUSTIC INSULATION TO FILL
STUD CAVITY DEPTH

6" METAL STUD @ 16" O.C.
UNLESS NOTED OTHERWISE IN
STRUCTURAL.

RESILIENT CHANNEL,
INSTALLED HORIZONTALLY @
24" O.C.

(2) LAYERS TYPE "X" GYP.
BD.

NOTE: AT WASTE PLUMBING,
WRAP PIPE W/ 1" INSULATION

4 3/4" | 4 1/4"
9"

FIRE RATING:	2-HR	UL DESIGN #:	U454 NLB
S.T.C. RATING:	55-59	TEST NO: RAL TL 83-214,9-1-83	

D PARTY WALL

1-1/2 = 1'-0"

(LOAD & NON-LOAD BEARING)